



PyroSol A100



Aerosol generating extinguishing system unit

Aerosol temperature: 61°C at 0.61 meters
Operation conditions: -40°C to + 54°C
Active mass: 100 gr.

WARNING:

Discharge can result in a potential hazard to personnel from the natural form of the agent. Avoid unnecessary exposure.

CAUTION:

- Keep the aerosol generator away from heat.
- Generator casing reaches high temperatures.
- Do not cover, remove or deface this label.
- Always adapt safety recommendations per Pyrosol manual for the Design, Installation and Maintenance p/n PyrosolManual.

IDENTIFICATION OF CONTENT:

- Solid content includes: Potassium Nitrate, Magnesium and Epoxy Resin polymer.

HEALTH	1
FLAMMABILITY	1
PHYSICAL HAZARD	1
PERSONAL PROTECTION	1

INSPECTIONS:

- The extinguishing system unit shall be inspected monthly, or at more frequent interval whenever circumstances requires. Dispose of aerosol generators properly after use.

REFERENCES and SOURCES:

- NFPA 2010, Standard for fixed Aerosol Fire Extinguishing systems.
- UL-2775, April 2014.
- PyroSol Manual: Design, Installation and Maintenance manual p/n PyrosolManual.
- PyroSol MSDS, February 2020.



PyroSol A100



Aerosol generating extinguishing system unit

Aerosol temperature: 61°C at 0.61 meters
Operation conditions: -40°C to + 54°C
Active mass: 100 gr.

Serviceable life – 15 years

Serial number

Production date

Replacement date

Manufacturer:

Pyro Engineering Corp.

409-11, 38-9, Digital-ro 31-gil, Guro-gu, Seoul, 08376,
Republic of Korea